


Thermodynamic analysis of the partially evaporating trilateral cycle

S. Lecompte

M. van den Broek


M. De Paepe

Next Generation Organic Rankine Cycles



Why advanced cycle architectures?

- Improve **efficiency**
 - Increase cost effectiveness
 - Beneficial for the environment
- Increase **operating range** to lower input temperatures



Heat input and efficiency

$$\dot{W}_{out,net} = \eta_{th} \cdot \dot{Q}_{heat,in}$$

↑ ↑ ↑


Thermal efficiency

- $\eta_{th,carnot} = 1 - \frac{T_L}{T_H}$



- T_L ↓
- T_h ↑



Heat input





The Trilateral cycle



Trilateral cycle: overview

- 14% to 20% **net power improvement** versus basic ORC
Fischer et al.
- **Two-phase expander** needed
- **High volume ratio over expander** Smith et al.
 - Water/steam not suitable
- Expanders with high isentropic efficiency possible
 - double screw expanders
- Resulted in own study: **partially evaporating TLC**


Cycle with partial evaporation



- Increased power output compared to subcritical ORC
 - Reduced pump size compared to TLC
- Reduced volume ratio over expander compared to TLC


Trilateral cycle: results partial evaporation (R245fa)

Cycle	Isentropic pump efficiency	30%
	Isentropic turbine efficiency	70%
	Subcooling	3°C
	ΔT pinch evaporator	5°C
	ΔT pinch condenser	5°C
Heat source	Inlet temperature waste heat	100/120/140 °C
	Mass flow rate waste heat	1 kg/s
Heat sink	Inlet temperature cooling water	20 °C
	Outlet temperature cooling water	30 °C




Thermodynamic analysis of partially evaporating TLC, Submitted abstract, ORC2013


Trilateral cycle: results volume ratio




Effect on UA value



Effect of pump isentropic efficiency



Effect of heat carrier temperature



Conclusions

- Increase in power output with 29% compared to subcritical ORC
- Reduction in pumping power with 24% compared to pure TLC
- Volume ratio 3 times lower compared to TLC
- Decrease in UA value with 20% compared to TLC
- Partial evaporation is promoted when the pump isentropic efficiency is low

Thermodynamic analysis of the partially evaporating trilateral cycle

S. Lecompte

M. van den Broek

M. De Paepe